

**Proposed Rack Layout for
PSnet Equipment at
1 Ashburton Site**

	U's	Inches		Inches	U's	
24	24.0	42		0.875	0.5	1
	23.5	41.125		1.75	1.0	
23	23.0	40.25		2.625	1.5	2
	22.5	39.375		3.5	2.0	
22	22.0	38.5		4.375	2.5	3
	21.5	37.625		5.25	3.0	
21	21.0	36.75		6.125	3.5	4
	20.5	35.875		7	4.0	
20	20.0	35		7.875	4.5	5
	19.5	34.125		8.75	5.0	
19	19.0	33.25		9.625	5.5	6
	18.5	32.375		10.5	6.0	
18	18.0	31.5		11.375	6.5	7
	17.5	30.625		12.25	7.0	
17	17.0	29.75		13.125	7.5	8
	16.5	28.875		14	8.0	
16	16.0	28	Shelf for microwave radio power supplies	14.875	8.5	9
	15.5	27.125		15.75	9.0	
15	15.0	26.25		16.625	9.5	10
	14.5	25.375		17.5	10.0	
14	14.0	24.5	Cat 6 Patch Panel	18.375	10.5	11
	13.5	23.625		19.25	11.0	
13	13.0	22.75	Fiber LIU	20.125	11.5	12
	12.5	21.875		21	12.0	
12	12.0	21	** Reserve Space **	21.875	12.5	13
	11.5	20.125		22.75	13.0	
11	11.0	19.25	Fiber Switch Stack 1:1	23.625	13.5	14
	10.5	18.375		24.5	14.0	
10	10.0	17.5	Fiber Switch Stack 1:2	25.375	14.5	15
	9.5	16.625		26.25	15.0	
9	9.0	15.75	** Reserve Space **	27.125	15.5	16
	8.5	14.875		28	16.0	
8	8.0	14	Fiber Switch Stack 2:1	28.875	16.5	17
	7.5	13.125		29.75	17.0	
7	7.0	12.25	Fiber Switch Stack 2:2	30.625	17.5	18
	6.5	11.375		31.5	18.0	
6	6.0	10.5	** Reserve Space **	32.375	18.5	19
	5.5	9.625		33.25	19.0	
5	5.0	8.75	Tripp Lite PDU	34.125	19.5	20
	4.5	7.875		35	20.0	
4	4.0	7	Tripp Lite UPS	35.875	20.5	21
	3.5	6.125		36.75	21.0	
3	3.0	5.25		37.625	21.5	22
	2.5	4.375		38.5	22.0	
2	2.0	3.5	Tripp Lite UPS	39.375	22.5	23
	1.5	2.625		40.25	23.0	
1	1.0	1.75		41.125	23.5	24
	0.5	0.875		42	24.0	